STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121647
Permit No.
Basin 059

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72095

1. OWNER George Le Bracht
MAILING ADDRESS 3035 Horseshoe Dr. Battle MTN NV 89820
ADDRESS AT WELL LOCATION 2995 Horseshoe Dr. Battle MTN NV 894820
Subdivision Name: County: LANDER

2. LOCATION SW ¼ SE ¼ Sec 12 T 31 N/S R 45 E
PERMIT/WAIVER No. 11-455-12
Issued by Water Resources Parcel No.
Latitude
Longitude
UTM E 512923 ☒ NAD 27
N 4490718 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	10	10
Sandy Clay		10	30	20
Sand & Gravel		30	50	20
Sandy Clay		50	60	10
Rocky Clay		60	80	20
Sand & Gravel		80	90	10
Soft Rocky Clay		90	100	10
Sand & Gravel		100	120	20
NAD 27				
40.569037°N				
116.847335°W				

RECEIVED 2015 JAN 22 AM 11:12 STATE ENGINEERS OFFICE

Date started: 01-08, 2015
Date completed: 01-10, 2015

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation SAWed (PVC)
Size of perforation 3/16 X 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout 5 to 40 ☐ Pumped ☒ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 90 to 120 ☐ Pumped ☒ Poured
Type: 3/8 —
Bentonite Chips: ☐ Yes ☐ No 40 to 90 ☐ Pumped ☒ Poured
Type: 3/8

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	200+	Unk	2 Hrs

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC.
Contractor
Address P.O. BOX 902 - Winnemucca, NV 89446
Contractor
Nevada contractor's license number issued by the *State Contractor's Board* 0009605A
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1807
Signed Joe Boggio
By driller performing actual drilling on site or contractor Joe Boggio
Date

(Rev 06-08)

USE ADDITIONAL SHEETS IF NECESSARY