STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121660
Permit No.
Basin No. 070

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72331
WELL NAME (*if applicable*):

1. OWNER/CLIENT NAME John Prado
MAILING ADDRESS 5875 Bird Lane
Winnemucca NV 89445

DETAILED ADDRESS AT WELL LOCATION 5875 Bird Lane
Winnemucca NV 89445
Subdivision Name: JB Estates *County:* Humboldt

2. PLS LOCATION SE ¼ SE ¼ 2 Sec 35 N/S 37 E
PERMIT/WAIVER NO. 3537-02-477-008
Issued by Water Resources *Current Parcel No.*

Latitude N 40*55'1.476 UTM E ☐ NAD 27
Longitude W117*46'41.624 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand		No	0	6
Sand and clay		N	6	65
Sand and clay		Y	65	140
Gravel sand and clay		Y	140	165
Sand and clay		Y	165	200

NAD 27
40.931062°N
117.777265°W

Date started: 5-Jan, 20 15
Date completed: ~~08/04/15~~ 1-8, 20 15

7. WATER QUALITIES
Static water level: 62 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ~~cold~~ 64° Fahrenheit
Water Quality: clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30	N/A	8

9. CONSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8"	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	Steel	.188"	0	20
6 5/8"	PVC	Sched 40	20	200

ANNULAR MATERIALS

Sanitary Seal x ☐ Yes ☐ No x
☒ Neat Cement 0 to 20 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ Bentonite Chips 20 to 55 ☐ Pumped ☒ Poured
☒ Gravel Pack [> 0.2 in.] 55 to 200 ☐ Pumped ☒ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.02
From 0 Feet To 200 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc
Contractor
Address 5140 Jungo Rd Winnemucca NV
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 76778
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1563
Signed:
By driller performing actual drilling on site or contractor
Date: 1-14-15

RECEIVED 2015 JAN 23 AM 11:2 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.