STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121673
Permit No. 84124
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER BLAIR & DEYANIRA IVERSON
MAILING ADDRESS 7340 DARLING RD
LAS VEGAS NV 89131

ADDRESS AT WELL LOCATION 5330 S GOLDEN VALLEY
PAHRUMP
SUNLAND ESTATES NYE

37282

2. LOCATION SE NW 8 21S 54
PERMIT/WAIVER No. 84124 45-114-02
Parcel No.

N36°08'33.7"
W115°56'21.1"
☐ ☒ NAD NW/SS 54

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strip	From	To	Thickness
SAND & CLAY		0	50	50
CLAY & SANDSTONE		50	70	20
CALICHIE	WB	70	80	10
CLAY & SANDSTONE		80	105	25
CALICHIE	WB	105	140	35
CEMENTED SAND	WB	140	200	60
CLAY & CALICHIE	WB	200	240	40
SANDSTONE & CLAY	WB	240	280	40
CLAY		280	300	20

DCNR/DWR/SNBC
RECEIVED
JAN 23 2015

Date started: 16-Jan, 20 15
Date completed: 18-Jan, 20 15

7. Water Level
Static water level: 67 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

		From		To	
12 1/4" ~~11~~	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	300

Type of perforation SCREEN
Size of perforation .032
From 160 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 55 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 55 to 300 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the 2513
Signature [signature]
By driller performing actual drilling on site or contractor
1/19/2015

2015 MAR 12 AM 9:19
STATE ENGINEER'S OFFICE

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 36.1427314 -115.9383382

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 12Ke73
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.[illegible]

Well Log Id. 37282

1. OWNER BLAIR & DEYANIRA IVERSON
MAILING ADDRESS 7340 DARLING RD
LAS VEGAS NV 89131

ADDRESS OF WELL LOCATION 5330 S GOLDEN VALLEY
PAHRUMP
Subdivision SUNLAND ESTATES NYE

2. LOCATION SE NW Sec. 8 T. 21S N/S R. 54 E
PERMIT/WAIVER No. 84124 45-114-02
Parcel No.
Latitude N36°08'33.7"
Longitude W115°56'21.1"
☐ NAD 27 ☒ NAD 83/WASS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & CLAY		0	50	50
CLAY & SANDSTONE		50	70	20
CALICHIE	WB	70	80	10
CLAY & SANDSTONE		80	105	25
CALICHIE	WB	105	140	35
CEMENTED SAND	WB	140	200	60
CLAY & CALICHIE	WB	200	240	40
SANDSTONE & CLAY	WB	240	280	40
CLAY		280	300	20

DCNR/DWR/SNBC
RECEIVED
MAR 13 2015

Date started 16-Jan , 20 15
Date completed 18-Jan , 20 15

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

		From		To	
12-1/4	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	300

Perforations
Type of perforation SCREEN
Size of perforation .032
From 160 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 55 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 55 to 300 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level 67 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the 2513
Signed [signature]
By driller performing actual drilling on site or contractor
1/19/2015

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY