STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121738
Permit No. 82618-T
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69999

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain, Nevada, 89045

ADDRESS AT WELL LOCATION Round Mountain Pit, south ramp
Well Name:DW-71

2. LOCATION SE ¼ NE ¼ Sec 30 T 10N N/S R 44 E
PERMIT/WAIVER No. ~~82618 N/A~~ (Issued by Water Resources) N/A Parcel No.

Latitude
Longitude
UTM E 493481.336 ☑ NAD 27
N 4283202.226 ☐ NAD 83/WGS 84
Subdivision Name: N/A County: Nye

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite type 8		0	1185	1185
180 ft.	x			

Nad 27
38.699286 N
117.074962 W

Date started 29-Mar , 20 13
Date completed 28-Apr , 20 13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
airlift 1000'	160	466	8

8. WELL CONSTRUCTION
Depth Drilled 1185 Feet Depth Cased 1180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
26	Inches	0	Feet	40	Feet
19	Inches	40	Feet	1185	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	86.61	.375	0	40
12.75	33.375	.25	+3	1180
2.375	4.38	.1875	+2	1000

Perforations:
Type of perforation louvered (sounder is slotted .125)
Size of perforation 0.125
From 200 feet to 320 feet
From 360 feet to 560 feet
From 640 feet to 960 feet
From 1000 feet to 1160 feet
From (sounder)900 feet to 1000 feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 146 feet to 1185 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow No G.P.M N/A P.S.I
Water temperature 131 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 580 West Silver Street (Contractor)
Elko Nevada 89801
Nevada contractor's license number issued by the *State Contractor's Board* 00075355
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2457
Signed (By driller performing actual drilling on site or contractor)
Date april 30,2013

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY