

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121739
Permit No. _____
Basin No. 107

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68128
WELL NAME (If applicable): _____

1. OWNER/CLIENT NAME Richard Murti
MAILING ADDRESS 91 Albright Smithville 89430

DETAILED ADDRESS AT WELL LOCATION 91 Albright Smithville
Subdivision Name: _____ County: Lyon

2. PLS LOCATION NE 1/4 NE 1/4 32 Sec 11 N/S 24 E
PERMIT/WAIVER NO. 016-601-03
Issued by Water Resources Current Parcel No.

Latitude 38° 07' 09" UTM E NAD 27
Longitude 119° 31' 38.5" UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Mining / Dewater Test / Other
 Irrigation Com / Ind Mun / QM
 Monitor Stock Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

| Material Encountered | Lost Circ. | Water Strata | From | To | Thickness |
|---|------------|--------------|------|-----|-----------|
| Dirt & Gravel | | | 0 | 28 | 28 |
| Cobbles & Sand | | | 28 | 79 | |
| Chip Rock & Sand | | | 79 | 182 | |
| Dense Brown Clay | | | 182 | 280 | 98 |
| Boulder | | | 280 | 293 | |
| Large Sand & Multi Colored Chip Rock | | | 293 | 327 | |
| Sand & Multi Colored Chips, Streaks of Clay | | | 327 | 340 | |

7. WATER QUALITIES
Static water level: N/A Feet below land surface
Artesian Flow: No G.P.M. 30+ P.S.I.
Water Temperature: Cold ° Fahrenheit
Water Quality: Clear

9. WELL CONSTRUCTION
Depth Drilled: 340 Feet
Depth Cased: 340 Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
Inches _____ Feet _____
Inches 9 7/8 Feet 100 Feet
Inches 10.0 Feet 340 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | | <u>.188</u> | <u>+1</u> | <u>20</u> |
| <u>6 7/8</u> | | <u>SDR 21</u> | <u>20</u> | <u>340</u> |

PERFORATIONS:
Type of perforation: Factory Cut
Size of perforation: 3/32
From 340 Feet To 320 Feet
From 300 Feet To 280 Feet

ANNULAR MATERIALS
 Sanitary Seal 0 to 54
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout 0 to 54 Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Bentonite Grout _____ to _____ Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] 54 to 340 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

8. WELL TEST DATA
Test Method: Bailer Pump Air Lift
G.P.M. _____ Draw Down (Feet Below Static) _____ Recorded Time (Hours) _____
30+ _____ 4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC.
Address P.O. Box 1255 Carson City, NV 89702

Nevada contractor's license number as issued by the State Contractor's Board: 46498A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2134
Signed: _____
Date: 2-2-15