STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 12124
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72972
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME SHARON HILL
MAILING ADDRESS 1604 VIEWMONT CT
GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION 1604 VIEWMONT CT
GARDNERVILLE, NV 89410
Subdivision Name: *County:* Douglas

2. PLS LOCATION SW ¼ NW ¼ 35 Sec 13 N/S 20 E
PERMIT/WAIVER NO. 1320-35-001-005
Issued by Water Resources *Current Parcel No.*

Latitude 38.950337*N UTM E ☐ NAD 27
Longitude 119.71342*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# N/A
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OLD 8 5/8 WELL			0	115
COURSE DG SANDS			115	168
BROWN CLAY			168	175
DG SANDS			175	185
GRAY CLAY SILTY			185	205
FRACTURED DG SANDS GRAVELS		XXX	205	250

Nad 27
38.950429 N
119.71241° W
deepens unknown log

Date started: 2-Feb , 20 15
Date completed: 4-Feb , 20 15

7. WATER QUALITIES
Static water level: 75 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: 51*

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25	30	3 HRS

9. INSTRUCTION
Depth Drilled: 135 Feet Depth Cased: 135 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 7/8 Inches	115 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.26	.216	110	250
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	N/A	to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	N/A	to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 0.032

From	To
210 Feet	250 Feet
Feet	Feet
Feet	Feet
Feet	Feet
Feet	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1905
Signed: Michael Hack
By driller performing actual drilling on site or contractor
Date: 2/4/2015

RECEIVED FEB 11 2015 DIVISION OF WATER RESOURCES

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.