

Well Log #
121765



Stantec Consulting Services Inc.
1165 East Jennings Way, Suite 101
Elko, NV 89801-7977
Tel: (775) 738-8766
Fax: (775) 738-2264

595 Double Eagle Court, Suite 2000
Reno, NV 89521-9005
Tel: (775) 747-5777
Fax: (775) 747-2177

**Valmy Power Plant
Summary Log of Replacement Monitoring Well**

MW-2RR: Completed 01/25/2015

Well Number	From	To	Interval	Lithology	Groundwater
MW-2RR	0	17	17	Sand with silt lenses	--
	17	42	25	Silt or clay with sand lenses	--
	42	90	48	Basalt with argillized breccias	Water at 64 feet

Notes: All intervals in feet below ground surface.
Groundwater depth as first encountered in drilling.



Walter M. Martin
Walter M. Martin, CPG-11358

2/11/15
Date

RECEIVED
2015 FEB 13 AM 11:23
STATE ENGINEERS OFFICE