STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121788
Permit No.
Basin No. 165

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68373
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Marian Vasser
MAILING ADDRESS Po 137 Genoa 89411

DETAILED ADDRESS AT WELL LOCATION 2311 Poplar St
Subdivision Name. *County:* Douglas

2. PLS LOCATION SE ¼ NE ¼ 9 Sec 13 N/S 19 E
PERMIT/WAIVER NO. DM 14.56 *Issued by Water Resources* 1319-09-602-020 *Current Parcel No.*

Latitude 39.00531 UTM E ☐ NAD 27
Longitude 119.84682 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well x Deepen: Orig WL# ?
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand/gravel			100	105
Clay			105	109
Cobbles/boulders			109	167
fractured rock			167	225

deepen within dug well
39.00562 N
119.84580 W

Date started: 1-2, 2015
Date completed: 1-3, 2015

9. CONSTRUCTION
Depth Drilled: 125 Feet Depth Cased: 225 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	85	Feet	225	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	.10	.188	85	225

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

PERFORATIONS:
Type of perforation: Factory Cut
Size of perforation: 3 3/32"x3
From 165 Feet To 225 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

7. WATER QUALITIES
Static water level: 85 Feet below land surface
Artesian Flow: no G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality: clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
15		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Blain Drilling *Contractor*
Address PO 1255 CC NV 89702 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 46498A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2134
Signed: *By person performing actual drilling on site or contractor*
Date: 2/11/2015

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.