

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY  
Log No. 121835  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37149

1 OWNER County of Clark (PK & Comm Serv)  
MAILING ADDRESS 500 S. Grand Central Pkwy  
Las Vegas, NV 89155

ADDRESS AT WELL LOCATION 5483 Clubhouse Dr  
Subdivision Name: \_\_\_\_\_ County: \_\_\_\_\_

2 LOCATION NW ¼ SE ¼ Sec 4 T 21S N/S R 62 E  
PERMIT/WAIVER No. DW-1340 16104701002  
Issued by Water Resources Parcel No.

Latitude UTM 812897.1  NAD 27  
Longitude N 26 756099.5  NAD 83/WGS 84  
State Plane

3 TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

Is this well being plugged because a replacement well was drilled? no  
If yes, what is replacement well NOI? \_\_\_\_\_  
Is there an existing well log? \_\_\_\_\_  
If yes, what is NDWR well log #? \_\_\_\_\_

4 EXISTING WELL CONSTRUCTION  
Depth Drilled 50 Feet Depth Cased 50 Feet

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: \_\_\_\_\_

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	3/8	0	50

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no  
If casing was left in place, please show where additional perforations were made:  
Additional Perforations: \_\_\_\_\_  
Type of perforater used: \_\_\_\_\_

Existing Perforations:

Type of perforation	Size of perforation	From	To
machine slotted	0.032	30 feet	50 feet

From	To	Number of perfs per linear foot

5 WATER LEVEL  
Static water level \_\_\_\_\_ feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ ° F Quality \_\_\_\_\_

8 WELL PLUGGING MATERIALS  
Material Used  
From 2 feet to 10 feet concrete grout  Pumped  Poured  
From 10 feet to 12 feet bentonite chips  Pumped  Poured  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet \_\_\_\_\_  Pumped  Poured  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet \_\_\_\_\_  Pumped  Poured  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet \_\_\_\_\_  Pumped  Poured

6 Additional Notes or Comments

LVP Well #132

SEP 24 2014

Neat Cement Fluid Weight 94/7 lbs/gal  
Bentonite Grout % bentonite  
Date Started 4/22/2014  
Date Completed 4/22/2014

9 DRILLER'S CERTIFICATION  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
Name Viking Drillers Inc Contractor  
Address 5950 Granite Lake Dr. Contractor  
Granite Bay, CA 95691  
Nevada contractor's license number 0034680 issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller DW-2361  
Signed \_\_\_\_\_  
Date 7/31/2014

USE ADDITIONAL SHEETS IF NECESSARY

36.1485133  
- 115.0516231  
NAD 27