STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121871
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37285

1. OWNER STEVE & SARAH HAMRICK
MAILING ADDRESS 1231 BRIAN RD
PAHRUMP NV 89048

ADDRESS AT WELL LOCATION 1231 BRIAN RD
PAHRUMP
Subdivision Name: TUKWILA RANCHOS County: NYE

2. LOCATION SW ¼ NW ¼ Sec 11 T 21S N/S R 53 E
PERMIT/WAIVER No. 44-421-08
Issued by Water Resources Parcel No.

Latitude N36°08'24.2"
Longitude W115°59'18.9"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & CLAY		0	90	90
CALICHIE		90	102	12
CLAY		102	122	20
CALICHIE	WB	122	160	38
CEMENTED SAND & GRAVEL	WB	160	190	30
CLAY & GRAVEL		190	200	10
CALICHIE	WB	200	220	20

DCNR/DWR/SNRC RECEIVED FEB 18 2015

Date started: 6-Feb , 20 15
Date completed: 6-Feb , 20 15

9. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9-7/8	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.37	.248	0	220

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 140 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 6.240 to 0 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 85 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2513
Signed
*By driller performing actual drilling on site or contractor
Date 2/9/2015

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY

36,1400928
-115,9877258
NAD 27