STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121872
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72923
WELL NAME *(If applicable)*: B-03

1. OWNER/CLIENT NAME Yarrow LLC - C/O Premier Trust
MAILING ADDRESS 4465 S. Jones Blvd
Las Vegas, NV 89013

DETAILED ADDRESS AT WELL LOCATION 2300 S. Maryland Prkwy
Las Vegas, NV 89014
Subdivision Name: *County:* Clark

2. PLS LOCATION SE ¼ SE ¼ 3 Sec 21 N/S 61 E
PERMIT/WAIVER NO. 162.03.802.004
Issued by Water Resources *Current Parcel No.*

Latitude 36* 08' 43.93" UTM E ☒ NAD 27
Longitude 115* 08' 14.07" UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	0.2'
Silty Sand w Gravel			0.2'	4'
Caliche			4'	8'
Csilty Clay			8'	20'

Date started: 22-Jan , 20 15
Date completed: 22-Jan , 20 15

NV DNR/DWR/SNRP
RECEIVED
FEB 1 9 2015

7. WATER QUALITIES
Static water level: 7.50' Feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 20 Feet Depth Cased: 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.25	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	-.154	-.5	20

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0.5'	to	6'	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	6'	to	8'	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	8'	to	20'	☐ Pumped	☒ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

From	Feet	To	Feet
10	Feet	20	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP
Contractor
Address 5241 Schirlls St. Las Vegas, NV 89118
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 0075355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2512-LTD
Signed: Bob H
By driller performing actual drilling on site or contractor
Date: 2/5/2015

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.

NAD 27
36.1455361
-115.1372416