STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121905
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36845

1. OWNER Sahara Las Vegas Corp.
MAILING ADDRESS 3221 S. Torrey Pines Las Vegas, NV. 89146
ADDRESS AT WELL LOCATION 2601 S. Las Vegas Blvd Las Vegas, NV. 89109
Subdivision Name: County: Clark

2. LOCATION SE¼ NE¼ Sec. 9 T. 21 N/S R. 61 E/W
PERMIT/WAIVER No. MO-3000 Issued by Water Resources
162-09-602-001 Parcel No.
Latitude 36.14007
Longitude -115.15926
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL CLAY/SAND		0	3	3
SILTY SAND		3	9	6
SILTY CLAY		9	14	5
SANDY GRAVEL		14	19	5
SANDY CLAY	wet	19	24	5
SILTY CLAY		24	39	15
SANDY CLAY		39	49	10
SILTY CLAY		49	54	5
SANDY GRAVEL	wet	54	59	5
SILTY CLAY		59	80	21

DCNR/DWR/SNBC RECEIVED DEC 22 2014

Date started: 11/18, 20 14
Date completed: 11/18, 20 14

7. Water Level
Static water level: 20 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" sch 40 PVC			0	80

Perforations:
Type of perforation Factory Slots
Size of perforation .021
From 20 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	0 to 16		☐ Pumped	☒ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 18 to 80 ☐ Pumped ☒ Poured
Type: #12 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 16 to 18 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Hole Plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling, Inc. (Contractor)
Address 4255 W. Post Rd. (Contractor)
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas N. Beall (By driller performing actual drilling on-site or contractor)
Date 12/18/14

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

36.140099
-115.1584267
NAD 27

(NSPO 3-08) (O) 627