WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 121913
Permit No.
Basin

NOTICE OF INTENT NO. 33124

1. OWNER Doug and Barbara Stoddard
MAILING ADDRESS 6110 S. Tequilla Way
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
6110 S. Tequilla (36D 7' 48.29"N 115D 59' 42.4" W)
Latitude Longitude

2. LOCATION N/E 1/4 N/E 1/4 Sec. 15 T 21S N/S R 53E E Nye County
PERMIT NO. ____ Issued by Water Resources | 44-692-04 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Steel Casing	x	0	140	140
brown loam	x	140	205	65
brown clay with gravel	x	205	210	5
brown loam	s	210	260	50

DCNR/DWR/SNBC RECEIVED DEC 1 8 2014

Original well log # 46779

Date started 11/17/1914 2014, 19__
Date completed 11/18/1914, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	260 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	260

Perforations:
Type perforation sawcyt
Size perforation .188
From 200 feet to 220 feet
From 240 feet to 260 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 5801 S. Homestead (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 12-15-14

36.1301176
-115.9942537
NAD 27