

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 121916
Permit No. 12790
Basin 162

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 37280

1 OWNER <u>NYE COUNTY PUBLIC WORKS</u> MAILING ADDRESS <u>250 N HWY 160, STE #2</u> <u>PAHRUMP NV 89060</u>		ADDRESS AT WELL LOCATION <u>5301 E MANSE RD</u> <u>PAHRUMP</u>	
2 LOCATION NE 1/4 NE 1/4 Sec 8 T 21S N/S R 54 E		Latitude <u>N36°08'46.9"</u>	UTM E <input type="checkbox"/> NAD 27
PERMIT/WAIVER No. <u>12790</u>	<u>45-101-69</u>	Longitude <u>W115°55'19.1"</u>	N <input checked="" type="checkbox"/> NAD 83/WGS 84
Issued by Water Resources		Parcel No.	
Subdivision Name		County <u>NYE</u>	

3 TYPE OF WELL		Is this well being plugged because a replacement well was drilled? <u>NO</u>	Is there an existing well log? <u>YES</u>
<input type="checkbox"/> Domestic	<input checked="" type="checkbox"/> Irrigation	<input type="checkbox"/> Test	
<input type="checkbox"/> Municipal/Industrial	<input type="checkbox"/> Monitor	<input type="checkbox"/> Stock	If yes, what is NDWR well log #? <u>2135</u>
If yes, what is replacement well NOP?			

4 EXISTING WELL CONSTRUCTION

Depth Drilled 505 Feet Depth Cased 505 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>	<u>UK</u>		<u>0</u>	<u>159</u>
<u>12</u>	<u>UK</u>		<u>159</u>	<u>505</u>

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth? yes no

If well was not cleaned out to total depth, please explain why: THE CASING COLLAPSED @ 310'

Existing Perforations:

Type of perforation	EXISTING
Size of perforation	
From	feet to

Was the well contaminated? yes no

Was the casing pulled? yes no

Was the casing over drilled? yes no

If casing was left in place, please show where additional perforations were made:

Additional Perforations:

Type of perforator used:	USED EXISTING
From	feet to

5 WATER LEVEL

Static water level feet below land surface

Artesian flow G.P.M. P.S.I.

Water temperature °F Quality

8 WELL PLUGGING MATERIALS

Material Used			
From <u>310</u> feet to <u>8</u> feet	<u>CEMENT GROUT</u>	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

6 Additional Notes or Comments

WE RAN A VIDEO ON WELL & THE CASING WAS IN BAD SHAPE & HAD A LOT OF HOLES & OPEN PERFS. THE WELL HAD FILL @ 264'. We CLEANED OUT TO 310' WHERE WE HIT WHAT FELT LIKE COLLAPSED CASING. PLUGGED UNDER WAIVER R-1668. CASING CUT OFF 8' BELOW SURFACE.

Neat Cement Fluid Weight 15.5 lbs/gal

Bentonite Grout % bentonite

Date Started 12/23/2014

Date Completed 1/7/15

DCNR/DWR/SNB0
RECEIVED
JAN 12 2015

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING
Contractor

Address 1220 MANSE RD
Contractor

PAHRUMP NV 89048

Nevada contractor's license number 47333
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 1/8/2015

RECEIVED
 12 JAN 9 2015
 DIVISION OF WATER RESOURCES

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

NAD 27
 36.146398
 -115.9211164