WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 121934
Permit No.
Basin 207

NOTICE OF INTENT NO. 72477

1. OWNER Thomas Augustine
MAILING ADDRESS 764 Skip Jack Drive
Henderson Nevada

ADDRESS AT WELL LOCATION
LoT 24 Forest Moon Acres
Nye County, Nevada

2. LOCATION NW ¼ SE ¼ Sec. 13 T. 6 S R. 60 E. Nye County County
PERMIT NO. 013-803-02 Forest Moon Acres
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt		0	7	7
Gravel	✓	7	14	7
Clay		14	17	3
Sand		17	18	1
Clay		18	23	5
Gravel	✓	23	25	2
Clay Sand		25	32	7
Gravel	✓	32	40	8
Clay & Sand	✓	40	93	53
Rock + Clay		93	95	2
Clay & Sand	✓	95	140	45

Nad 27
38.375518°N
115.178898°W

Date started 12-7-2014, 20
Date completed 12-12-2014, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
7.5	125	12 hrs

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.3	.250	0	20
6.625	4.95	Schedule 120	20	140

Perforations:
Type perforation Factory Saw
Size perforation .032
From 60 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 52 Ft
Placement Method: ☑ Pumped ☐ Poured

Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 140 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 55 °F Quality PH 9.2, 186 TDS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name David Gibson Contractor LLC
Contractor
Address PO Box 203, Land Nevada 89317
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0077887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2315
Signed Jimmy H Eldridge
By driller performing actual drilling on site or contractor
Date 12-18-2014

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627