WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 121935
Permit No. 77014
Basin 207

NOTICE OF INTENT NO. 68399

1. OWNER Orvan & Jolynn Maynard
MAILING ADDRESS Po Box 64 Lund, NV 89317
ADDRESS AT WELL LOCATION 1300 N pole Line Rd. N 38° 52.952' W 115° 02.530' wgs 84

2. LOCATION NE ¼ SE ¼ Sec. 19 T. 12 N/S R. 62 E. White Pine County

PERMIT NO. 77014 (Issued by Water Resources) | 013-072-01 (Parcel No.) | none (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Clay		0	7	
tan silty clay		7	12	
tan silt gravel		12	14	
tan silty clay		14	20	
tan gravel		20	22	
tan clay silt gravel		22	51	
clay		51	53	
gravel	water	53	55	3
tan clay silt		55	58	
gravel	water	58	59	1
tan clay silt		59	68	
gravel	water	68	71	3
clay		71	87	
gravel	water	87	97	10
tan silty clay		97	106	
gravel	water	106	108	2
clay-silt		108	125	
gravel	water	125	126	1
silty clay		126	140	
gravel	water	140	142	2
silty clay		142	158	
gravel	water	158	162	4
silt clay		162	175	
gravel	water	175	177	2
clay		177	180	
gravel	water	180	182	2
clay-silt		182	200	

Date started November 24, 2014
Date complated Feb 7, 2015

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	50	0	1
Nad 27			
38.882590°N			
115.0413160°W			

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
20 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	-18"	200

Perforations:
Type perforation mill
Size perforation ⅛ x 2.5" x 16 row
From feet to feet
From 60' feet to 180' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 53 feet to 200 feet

9. WATER LEVEL
Static water level 51' 9" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Maynard Well drilling (Contractor)
Address Po Box 64 Lund, NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 047226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Orvan Maynard
By driller performing actual drilling on site or contractor
Date Feb 24-15

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627