STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121959
Permit No. 83077
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39202
WELL NAME (*If applicable*): 2B

1. OWNER/CLIENT NAME First Solar
MAILING ADDRESS PO Box
Jean, NV 89019

DETAILED ADDRESS AT WELL LOCATION 1275 Primm Blvd.
Jean, NV 89019
Subdivision Name: *County:* Clark

2. PLS LOCATION SW ¼ SW ¼ 35 Sec 26S N/S 59 E
PERMIT/WAIVER NO. 83077 (*Issued by Water Resources*) 223-350-000-01 (*Current Parcel No.*)

Latitude 35° 38' 7.2996 UTM E ☐ NAD 27
Longitude 115° 20' 27.4092" UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ■ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ■ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand, Gravel			0	30
Gravel w/Sand			30	40
Sand, Minor Gravel			40	230
Gravel w/Sand			230	280
Sand w/Gravel			280	290
Gravel w/Sand			290	380
Sand w/Gravel			380	500
Gravel w/Sand			500	510
Sand w/Gravel			510	670

DCNR/DWR/SNDO RECEIVED MAR 06 2015

Date started: 22-Jan , 20 15
Date completed: 6-Feb , 20 15

9. INSTRUCTION
Depth Drilled: Feet Depth Cased: Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
36	Inches	0	Feet	50	Feet
20	Inches	50	Feet	670	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12.75	43	.3125	0	650

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
■ Cement Grout	0	to	50	■ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
■ Bentonite Chips	50	to	60	☐ Pumped	■ Poured
■ Gravel Pack [> 0.2 in.]	65	to	670	■ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Louvered
Size of perforation: 0.05

From	Feet	To	Feet
430	Feet	630	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. *WATER QUALITIES*
Static water level: 202 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ■ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
400	30	10

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Yellow Jacket Drilling (Contractor)
Address 3922 E. University Dr., Suite 1, Phoenix, AZ 85044 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* C23 58304A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2182
Signed: (*By driller performing actual drilling on site or contractor*)
Date: 3/2/15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

35.6353788
-115.3401215
NAD 27