STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121961
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34605
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME JERRY BURLEY
MAILING ADDRESS 1771 W. DYER ST.
PAHRUMP, NV 89048

DETAILED ADDRESS AT WELL LOCATION
1771 W. DYER ST. PAHRUMP, NV 89048
Subdivision Name: AL-VEGAS RANCHOS UT F L7 *County:* NYE

2. PLS LOCATION NW ¼ NW ¼ 17 Sec 20 S N/S 53 E
PERMIT/WAIVER NO. 036-273-31
Issued by Water Resources *Current Parcel No.*

Latitude N36° 12' 57.33" UTM E ☐ NAD 27
Longitude W116° 02' 46.78" UTM N ☒ NAD 83 (WGS 84)

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 27629
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
BROWN CLAY/CALICHE		X	140	200

Date started: 11-Feb, 20 15
Date completed: 11-Feb, 20 15

9. CONSTRUCTION
Depth Drilled: 60 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8 5/8	Inches	140	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.92	.28	0	200

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: ¼" WIDTH 4" LONG
From 160 Feet To 200 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

7. WATER QUALITIES
Static water level: 74 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Jim Pike Well Drilling, LLC (Contractor)
Address P. O. Box 56 Pahrump, NV 89041 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 17563A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1324
Signed: *(By driller performing actual drilling on site or contractor)*
Date: 03/02/15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.2159647
-116.0454666 NAD 27