STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121975
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37288

1. OWNER STEVE& SARAH HAMRICK
MAILING ADDRESS 1231 BRIAN RD
PAHRUM NV 89048

ADDRESS AT WELL LOCATION 4761 S MONEY ST
PAHRUMP NV 89048
Subdivision Name: MANKO County: NYE

2. LOCATION SW ¼ SE ¼ Sec. 2 T 21S N/S R 53 E
PERMIT/WAIVER No. 44-071-07
(Issued by Water Resources) Parcel No.

Latitude N36°08'59.5" Longitude W115°58'58.5"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING		0	140	140
CLAY		140	160	20
CALICHIE	WB	160	170	10
CLAY		170	190	20
CALICHIE	WB	190	200	10
CLAY		200	215	15
CALICHIE	WB	215	235	20
CLAY		235	250	15
CALICHIE	WB	250	260	10

original well log #65060

DCNR/DWR/SEO RECEIVED MAR 05 2015

Date started: 12-Feb, 20 15
Date completed: 13-Feb, 20 15

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	140	Feet
7-7/8	Inches	140	Feet	260	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	0	140
4.5	2.37	.248	0	240

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 180 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

EXISTING Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 0 to 260 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 84 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2513
Signed Vert Arias (By driller performing actual drilling on site or contractor)
Date 2/13/2015

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.1498986
-115.982059
NAD 27