# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121976
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 37292

1. OWNER LARRY & ELAIN GOINS
MAILING ADDRESS 2440 S RIVER PLATE DR
PAHRUM NV 89048

ADDRESS AT WELL LOCATION 2470 S RIVER PLATE DR
PAHRUMP
Subdivision Name: U5 CALVADA VALLEY County: NYE

2. LOCATION SE ¼ NE ¼ Sec 29 T 20S N/S R 53 E
PERMIT/WAIVER No. 040-252-10
Issued by Water Resources Parcel No.

Latitude N36°10'59.9" Longitude W116°02'08..4"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND & CLAY | | 0 | 45 | -45 |
| ROCK | | 45 | 60 | -15 |
| CLAY | | 60 | 118 | -58 |
| CALICHIE | | 118 | 130 | -12 |
| CLAY & GRAVEL | | 130 | 190 | -60 |
| CALICHIE | | 190 | 210 | -20 |
| CLAY & GRAVEL | | 210 | 245 | -35 |
| CALICHIE | WB | 245 | 250 | -5 |
| CLAY & GRAVEL | | 250 | 260 | -10 |
| CLAY & CALICHIE | WB | 260 | 300 | -40 |

CONFIDENTIAL RECEIVED MAR 05 2015

Date started: 27-Feb , 20 15
Date completed: 28-Feb , 20 15

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 9-7/8 | Inches | 0 | Feet | 300 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | 2.37 | .248 | 0 | 300 |
| | | | | |
| | | | | |

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 220 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 55 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 55 to 300 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 70 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2513
Signed
By driller performing actual drilling on site or contractor
Date 3/2/2015

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

36.1833444
-116.0348066
NAD 27