STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121693
Permit No. 83333
Basin 137B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71782

1. OWNER Round Mountain Gold Corp. DW-73
MAILING ADDRESS P.O. Box 480
Round Mountain, NV. 89045

ADDRESS AT WELL LOCATION Round Mountain Minesite, Round Mountain, NV
Subdivision Name: County: Nye

2. LOCATION NW¼SW¼ Sec19T10N/ R44E
PERMIT/WAIVER NO. 83333 (Issued by Water Resources) Order #1233 (Parcel. No.)

Latitude
Longitude
UTM E 492407 ☒ NAD 27
N 4284109 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Flooded Rev

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Light grey rock		0	40	40
Dark grey rock		40	190	150
Light grey rock		190	270	80
Light grey rock w/ clay		270	370	100
Dark grey rock		370	400	30
Light grey rock /w some clay		400	540	140
Dark and light grey rock		540	600	60
Very light grey rock		600	640	40
Dark grey rock		640	700	60
Grey clay		700	720	20
Dark grey rock		720	780	60
Very light grey rock		780	800	20

Nad 27
38.707449 N
117.097325°W

Date started: February 8, 20 15
Date completed: March 9, 20 15

7. Water Level
Static water level: 182 feet below land surface
Artesian Flow: N/A G.P.M. 40 P.S.I
Water Temperature: 89 °F
Quality: Fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		N/A

9. WELL CONSTRUCTION
Depth Drilled 806 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
26 Inches	0 Feet	20 Feet
19 Inches	20 Feet	806 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	86.61	.375	0	20
12.75	33.38	.250	+2	800

Perforations:
Type of perforation Louvered
Size of perforation .020
From 80 feet to 760 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 70 to 800 ☐ Pumped ☒ Poured
Type: 1/2" X 3/8" SRI Supreme
Bentonite Chips: ☒ Yes ☐ No 50 to 70 ☐ Pumped ☒ Poured
Type: 3/8" Holeplug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2486
Signed
By driller performing actual drilling on site or contractor
Date March 11, 2015

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com