STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 122007
Permit No. 62718
Basin 088

NOTICE OF INTENT NO. 72527 [redacted]

1. OWNER **Anchor Storage**
MAILING ADDRESS **16025 S. Virginia St**
Reno NV 89521

ADDRESS AT WELL LOCATION **16025 S. Virginia St**
Reno NV 89521
Subdivision Name: *County:* **Washoe**

2. LOCATION **SE¼SW¼** Sec**33**T**18N** / R **20** E
PERMIT/WAIVER NO. 62718 *Issued by Water Resources* **049-450-03** Parcel. No.

Latitude **39.375149** UTM E ☐ NAD 27
Longitude **-119.747237** N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☒ Other **Symmeterix**

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Sand & Gravel		122	133	11
Gray Clay & Gravel		133	155	22
Washoe County Permit #WL140080				
NAD 27 39.375238°N 119.746218°W				

Date started: **2/14**, 20 **15**
Date completed: **2/17**, 20 **15**

7. *Water Level*
Static water level: **106'** feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: **105** °F
Quality: **not tested**

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	**50+**		**2**

9. ***WELL CONSTRUCTION***
Depth Drilled **155** Feet Depth Cased **155** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 Inches	122 Feet	**155** Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	**10.79**	**.188**	102	**155**

Perforations:
Type of perforation **Mills Knife**
Size of perforation **1/4"**
From **120** feet to **150** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Bruce MacKay Pump & Well Service, Inc.** (CONTRACTOR)
Address **1600 Mt. Rose Hwy** (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the *State Contractor's Board* **23096**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **1790**
Signed [signature] By driller performing actual drilling on site or contractor
Date **2/24/15**

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

Deepens well log 17677