STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122030
Permit No.
Basin 101A

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71293

1. OWNER Kenneth Kite
MAILING ADDRESS PO Box 2281 Winnemucca, NV

ADDRESS AT WELL LOCATION Coal Canyon Road
Lovelock, NV
Subdivision Name: County: Pershing

2. LOCATION SW¼SE¼ Sec07T26N/ R34E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 015-340-10 (Parcel. No.)

Latitude 40.13'144" Longitude 118.20'133"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/clay		0	3	3
Cobbles		3	20	17
Gravel & Sand		20	50	30
Cobbles & Gravel		50	80	30
Brown Colechee		80	140	60
Black Colechee		140	160	20
Fractured Rock		160	180	20
Colechee		180	220	40
Black Shale/Colechee		220	340	120
Hard Rock		340	350	10
Brown Colechee		350	360	10
Black Rock Colechee		360	440	80
Sand & fines	X	440	460	20
Black Colechee		460	480	20

NAD 27
40.131529°N
118.200357°W

Date started: January 30, 20 15
Date completed: Feb 20, 20 15

7. Water Level
Static water level: 224 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1-2		5

9. WELL CONSTRUCTION
Depth Drilled 480 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches	0 Feet	480 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+18"	480

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32 X 4
From 460 feet to 480 feet
From 240 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 480 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☒ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed (By driller performing actual drilling on site or contractor)
Date March 20, 2015

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com