STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122043
Permit No.
Basin No. 073A

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72336
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Tracy Satowski
MAILING ADDRESS 10122 Golden Spur Ct.
Reno NV 89521

DETAILED ADDRESS AT WELL LOCATION Rock Creek Canyon
Off of Old Victory Hwy. Rye Patch Lovelock Nv.
Subdivision Name: *County:* Pershing

2. PLS LOCATION SW ¼ NE ¼ 3 Sec 29 N/S 33 E
PERMIT/WAIVER NO. 011-120-19
Issued by Water Resources *Current Parcel No.*

Latitude N40*24'29.064 UTM E ☐ NAD 27
Longitude W118*15'21.588 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log # ?
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Clay boulders gravel sand		No	0	45
Hard black shale		No	45	95
Hard grey granite		No	95	305
Hard grey granite with small fractur		Yes	305	575

RECEIVED
MAR 23 2015
STATE ENGINEER'S OFFICE

NAD 27
40.408166°N
118.255019°W

Date started: 6-Feb ,20 15
Date completed: 02/25/15 ,20 15

7. WATER QUALITIES
Static water level: 305 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 58 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
3	N/A	

9. CONSTRUCTION
Depth Drilled: 575 Feet Depth Cased: 575 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	0	Feet	100	Feet
6 ¼	Inches	100	Feet	575	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 ½	steel	.188	0	15
4 ½	pvc	Sched 40	15	575

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No X

☒ Neat Cement	0	to 20	☐ Pumped	☒ Poured	
☐ Cement Grout		to	☐ Pumped	☐ Poured	
☐ Concrete Grout		to	☐ Pumped	☐ Poured	
☒ Bentonite Chips	20	to 100	☐ Pumped	☒ Poured	
☒ Gravel Pack [> 0.2 in.]	100	to 575	☐ Pumped	☒ Poured	
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured	
☐ Other, explain:		to	☐ Pumped	☐ Poured	

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.02

From	Feet	To	Feet
295	Feet	575	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc. *Contractor*
Address 5140 Jungo Rd Winnemucca NV *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 76778
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1563
Signed: *By driller performing actual drilling on site or contractor*
Date: 3-19-15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.