STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122049
Permit No.
Basin 090

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72250

1. OWNER NEVADA PACIFIC DEVELOPMENT CORP.
MAILING ADDRESS 956 LAKESHORE BLVD.
INCLINE VILLAGE, NV. 89450

ADDRESS AT WELL LOCATION
593 LAKESHORE BLVD, INCLINE VILLAGE, NV. 89450
Subdivision Name: LOT 4 County: Washoe

2. LOCATION NE ¼ SE ¼ Sec 17 T 16N N/S R 18 E
PERMIT/WAIVER No. M/O 1981 (Issued by Water Resources) 122-100-23 Parcel No.

Latitude N39.24905' Longitude -119.97670'
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN TOP SOIL	0	0	1	1
BROWN SAND	0	1	24.5	24
BROWN SAND AND COBBLES	0	24.5	27	3
BROWN SAND	0	27	29	2
BROWN SAND AND COBBLES	37.6	29	31	2
BROWN SAND	37.6	31	40	9
B-21(B-M3)				
NAD 27				
39.248793°N				
119.975667°W				

Date started: 22-Mar, 20 15
Date completed: 23-Mar, 20 15

9. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.25	Inches	0	Feet	40	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH. 40	+2	40

Perforations:
Type of perforation FACTORY SLOT
Size of perforation .020
From 30 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 26 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 28 to 40 ☐ Pumped ☒ Poured
Type: 10/20 SILICA SAND
Bentonite Chips: ☒ Yes ☐ No 26 to 28 ☐ Pumped ☒ Poured
Type: 3/8 BENTONITE CHIPS

7. Water Level
Static water level: 37.6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: <85 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HAZ-TECH DRILLING, INC. (Contractor)
Address PO BOX 940 (Contractor)
MERIDIAN, ID. 83680
Nevada contractor's license number issued by the *State Contractor's Board* 0038018
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2246
Signed Joan Adams (By driller performing actual drilling on site or contractor)
Date 3/26/2015

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY

Plugged by well log 123717