STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122052
Permit No.
Basin No. 049

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72762
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME ARNOLD BECK CONSTRUCTION
MAILING ADDRESS 2147 GREENCREST DR
SPRING CREEK, NV 89815

DETAILED ADDRESS AT WELL LOCATION 1126 AMBER WAY
Subdivision Name: SPECIAL LANDS *County:* ELKO

2. PLS LOCATION SW ¼ NE ¼ 28 Sec 34N N/S 55 E
PERMIT/WAIVER NO. 006-09P-154
Issued by Water Resources *Current Parcel No.*

Latitude UTM E 602724 [X] NAD 27
Longitude UTM N 4517674 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Monitor
[ ] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [X] Rotary [ ] RVC
[X] Air [ ] Mud [ ] Sonic
[ ] Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
ALLUVIUM			0	10
LIGHT GREEN CLAYS			10	100
GREEN CLAYS			100	160
GREEN CLAYS w/ BLACK SHALE		XX	160	260

NAD 27
40.805554°N
115.782190° W

Date started: 26-Mar , 20 15
Date completed: 27-Mar , 20 15

7. *WATER QUALITIES*
Static water level: 99 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 83 ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
AT 260'-240'	40		2 HOURS
AT 180'	25		1 HOUR
AT 140'	15		1/2 HOUR
AT 120'	5		1/4 HOUR

9. CONSTRUCTION
Depth Drilled: 260 Feet Depth Cased: 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1.5	260

ANNULAR MATERIALS
Sanitary Seal [X] Yes [ ] No

[X] Neat Cement	4	to 25	[ ] Pumped	[X] Poured
[ ] Cement Grout		to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout		to	[ ] Pumped	[ ] Poured
[X] Bentonite Chips	25	to 55	[ ] Pumped	[X] Poured
[X] Gravel Pack [> 0.2 in.]	55	to 260	[ ] Pumped	[X] Poured
[ ] Sand Pack [< 0.2 in.]		to	[ ] Pumped	[ ] Poured
[ ] Other, explain:		to	[ ] Pumped	[ ] Poured

PERFORATIONS:
Type of perforation: PLASAMA CUT
Size of perforation: 3/16" X 4" 7 ROWS
From 240 Feet To 260 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name HACKWORTH DRILLING INC.
Contractor
Address P.O. BOX 850, ELKO, NV 89803
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 020582
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2329
Signed: *By driller performing actual drilling on site or contractor*
Date: 3/31/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.