

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 122098
Permit No. _____
Basin 10Z

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.176 and NAC 534.340

NOTICE OF INTENT NO. 72834 72834
WELL NAME (if applicable): _____

1 OWNER Ken Axelson ADDRESS AT WELL LOCATION 1115 4th Street
MAILING ADDRESS 1115 4th Street Silver Springs, NV
Silver Springs, NV Subdivision name _____ City Lyon

2 LOCATION SW SW Sec 7 T 17 N 25 E Latitude 39° 30' 13" N Longitude 119° 22' 53" W
PERMIT NUMBER 1017-148-03 UTM E 0308013 UTM N 4357760

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? yes
If yes, what is replacement well NO? 72811
Is there an existing well log? _____
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 70 Feet Depth Cased 70 Feet
7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.9	.188	+1	70

Was the well contaminated? yes no
Was the casing pulled? yes no If pulled from: _____ feet to _____ feet
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations

Existing Perforations
Type of perforator Holte
Size of perforation .250
From 25 feet to 70 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Type of perforator used: Holte
From 25 feet to 70 feet Number of perfs per linear foot 4
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
Static water level 56' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I. _____
Water temperature _____ °F Quality _____

6 Additional Notes or Comments

8 WELL PLUGGING MATERIALS
Material Used
From 0 feet to 70 feet Neat cement Pumped Poured
From _____ feet to _____ feet Pumped Poured
Neat Cement Fluid Weight 15 lbs/gal
Bentonite Grout _____ % bentonite

NAD 27
39.349853°N
119.227997°W

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Welsco Corporation Contractor
Address P.O. Box 888 Contractor
Fallon, Nevada 89406
Nevada contractor's license number _____
issued by the State Contractor's Board 0011752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed Jean Maurice
By driller performing special drilling on site or contractor
Date April 13, 2015

RECEIVED
2015 APR 14 AM 10:03
STATE ENGINEERS OFFICE

Plugs Unknown log