

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122107
Permit No. 166295 25895
Basin No. 107

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68318
WELL NAME (if applicable):

1. OWNER/CLIENT NAME John Tam Roy
MAILING ADDRESS 14500 Camino Real
Akasaders CA 93422

DETAILED ADDRESS AT WELL LOCATION 99 Jessen Rd
Subdivision Name: County: None

2. PLS LOCATION NE 1/4 NE 1/4 35 Sec 12 N/S 23 E
PERMIT/WAIVER NO. 166295 25895 010-14107
Issued by Water Resources Current Parcel No.

Latitude 37 51.871 UTM E Longitude 119 22.088 UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL#
 Replacement: Original well log # 3842
 Recondition: Original well log #

4. PROPOSED USE
 Irrigation Monitor
 Com / Ind Stock
 Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

| Material Encountered | Lost Circ. | Water Strata | From | To | Thick-ness |
|--------------------------|------------|--------------|------|-----|------------|
| SAND | | | 0 | 6 | |
| Clay | | | 6 | 24 | |
| SAND/clay | | | 24 | 33 | |
| Gravelly clay | | | 33 | 39 | |
| SAND & chip rock | | | 39 | 53 | |
| Clay - SAND - gravel | | | 53 | 92 | |
| SAND - Small Gravel | | | 82 | 135 | |
| Grey SAND & Small Gravel | | | 135 | 143 | |
| | | | 143 | 280 | |

9. WELL CONSTRUCTION
Depth Drilled: 280 Feet
Depth Cased: 280 Feet
HOLE DIAMETER (BIT SIZE)
13 3/4 Inches From 0 Feet To 280 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 7/8" | .22 | .188 | 12 | 280 |

PERFORATIONS:
Type of perforation: factory mill
Size of perforation: 3/32 x 3
From 100 Feet To 240 Feet
From 260 Feet To 280 Feet

ANNULAR MATERIALS
 Sanitary Seal 0 to 58
 Neat Cement to
 Cement Grout 0 to 58
 Concrete Grout to
 Bentonite Chips to
 Bentonite Grout to
 15% 20% Other, explain:
 Gravel Pack [> 0.2 in.] 58 to 280
 Sand Pack [< 0.2 in.] to
 Other, explain: to

Date started: 1-6-14, 20
Date completed: 1-10-14, 20

7. WATER QUALITIES
Static water level: 110 Feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: 60.9 ° Fahrenheit
Water Quality: clear

8. WELL TEST DATA

| Test Method: | Bailer | Pump | Air Lift | G.P.M. | Draw Down (Feet Below Static) | Recorded Time (Hours) |
|--------------|--------|------|-------------------------------------|--------|-------------------------------|-----------------------|
| | | | <input checked="" type="checkbox"/> | 80 | - | 10 hours |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Blair Drilling Contractor
Address: PO 1255 CC Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 46497
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller):
Signed: [Signature]
Date: 1-10-14