

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 12210  
Permit No. \_\_\_\_\_  
Basin No. 107

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72185  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Berrington Ranch MAILING ADDRESS 7 Miller Ridge Ct  
Wellington ND 58944 DETAILED ADDRESS AT WELL LOCATION 1 Miller Ridge Ranch  
Subdivision Name: \_\_\_\_\_ County: Mojo

2. PLS LOCATION SE 1/4 22 Sec 11 N/S 23 E Latitude 38°47'86.0 UTM E  NAD 27  
PERMIT/WAIVER NO. 000-091-23 Longitude 119°23'15.7 UTM N  NAD 83/WGS 84  
Issued by Water Resources Current Parcel No.

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# ?  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  Mining / Dewater  Com / Ind  Stock  Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
<u>clay-sand</u>			<u>110</u>	<u>205</u>	
<u>sandy gravel</u>			<u>205</u>	<u>230</u>	
<u>Mad 27</u>					
<u>39.797956W</u>					
<u>119.384955W</u>					
<u>deeper returns log</u>					

9. WELL CONSTRUCTION  
Depth Drilled: 170 Feet Depth Cased: 230 Feet  
HOLE DIAMETER (BIT SIZE)  
77/8" From 110 To 230  
Inches Feet Feet Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>112</u>	<u>.188</u>	<u>90</u>	<u>230</u>

PERFORATIONS:  
Type of perforation: factory  
Size of perforation: 3/32x3  
From 140 Feet To 230 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

ANNULAR MATERIALS

Sanitary Seal NA to \_\_\_\_\_  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 15 %  20 %  Other, explain: \_\_\_\_\_  
 Gravel Pack [ > 0.2 in. ] NA to \_\_\_\_\_  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

7. WATER QUALITIES  
Static water level: 85' Feet below land surface  
Artesian Flow: NA G.P.M. NA P.S.I.  
Water Temperature: 60.0 ° Fahrenheit  
Water Quality: clear

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name: BLAIN DRILLING & PUMP CO INC  
Address: P.O. Box 1255  
Carson City, NV 89702  
Contractor  
Nevada contractor's license number as issued by the State Contractor's Board: 46492A  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2139  
Signed: [Signature]  
Date: 6-10-14