

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 122125  
Permit No. \_\_\_\_\_  
Basin No. 092a

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72208  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Michael Barenbak  
MAILING ADDRESS 1470 Doric Dr  
Reno Nv 89503

DETAILED ADDRESS AT WELL LOCATION 1325 American Flat Rd  
Reno Nv 89508  
Subdivision Name Red Rock Estates County Washoe

2. PLS LOCATION SW  $\frac{1}{4}$  SE  $\frac{1}{4}$  33 Sec 22 N/S 19 E  
PERMIT/WAIVER NO 079-420-16  
Issued by Water Resources Current Parcel No

Latitude 39.72494 UTM E  NAD 27  
Longitude 119.85323 UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Monitor  
 Mining / Dewater  Corn / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Last Circ	Water Strata	From	To
Sand, brown clay, rock			0	20
tan clay, rock, sand			20	55
gravel, brown clay			55	90
black and white dig			110	165
fractured black and white dig			165	190
black and white dig			190	325
black and white dig and grey clay			325	395
grey and black fractured rock			395	460
TD 460				

9. INSTRUCTION  
Depth Drilled: 460 Feet Depth Cased: 460 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10 5/8	0	50
8 1/2	50	395
6 1/8	395	460

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	395
5	9.25	.188	380	460

ANNULAR MATERIALS  
Sanitary Seal  Yes  No

<input type="checkbox"/> Neat Cement	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout	0 to 50	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Bentonite Chips	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Gravel Pack [ > 0.2 in ]	50 to 395	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Sand Pack [ < 0.2 in ]	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Other, explain:	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Date started: 6-Nov . 20 14  
Date completed: 11-Dec . 20 14

7. WATER QUALITIES  
Static water level: 300 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: 68 ° Fahrenheit  
Water Quality: \_\_\_\_\_

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	20+	280	1 hr
	30	460	1 hr.

PERFORATIONS:  
Type of perforation: Factory  
Size of perforation: 3/32 x 3

From: <u>355</u>	Feet	To: <u>355</u>	Feet
From: <u>440</u>	Feet	To: <u>460</u>	Feet
From: _____	Feet	To: _____	Feet
From: _____	Feet	To: _____	Feet

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name A.S.A.P. Pump & Well Service, LLC. Contractor  
Address P.O. Box 60130 Reno, Nevada 89506 Contractor  
Nevada contractor's license number as issued by the State Contractors Board: 55387  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2362  
Signed: Larry Wells  
Date: 12/11/2014

RECEIVED  
2014 DEC 31 AM 11:22  
STATE ENGINEERS OFFICE