STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122170
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37428 37429

1. OWNER Clark County
MAILING ADDRESS 500 S. Grand Central Parkway
ADDRESS AT WELL LOCATION Overton NV
Muddy River Cooper St. Bridge
Subdivision Name: A County: Clark

2. LOCATION NW ¼ SE ¼ Sec 12 T 16S N/S R 67 E
PERMIT/WAIVER No. DW-1343 (Issued by Water Resources) 070-12-796-005 Parcel No.
Latitude 36° 33' 22.85" Longitude 114° 26' 36.19" UTM E ☑ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. ☒ Dewatering PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	15	15

9. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 + 1½ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
#23					
24	Inches	Surface	Feet	15	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16 3/4	39	1/4	+1½	15

Perforations:
Type of perforation Torch Cut
Size of perforation 1/16 x 4" 8 per FT
From 7 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☑ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☑ Yes ☐ No 7 to 15 ☐ Pumped ☑ Poured
Type: Pea gravel
Bentonite Chips: ☑ Yes ☐ No 4 to 7 ☐ Pumped ☑ Poured
Type: Hole plug

Date started: April 11, 20 14
Date completed: April, 20 14

CONSERVATION RECEIVED MAR 1 0 2015

7. Water Level
Static water level: 7 feet below land surface
Artesian Flow: G.P.M. 5 P.S.I.
Water Temperature: Cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mercsino Dewatering Inc. (Contractor)
Address 10162 East Cold Water Rd Davidson MI 48423 (Contractor)
00
Nevada contractor's license number issued by the State Contractor's Board 0074472
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2325
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date May 10 2014

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

36.5563472
-114.4433861
NAD 27

(NSPO 3-08) (O) 627