STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122286
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37849
WELL NAME *(If applicable)*: RISG3#5

1. OWNER/CLIENT NAME City of Henderson
MAILING ADDRESS 240 Water Street
Henderson NV 89015

DETAILED ADDRESS AT WELL LOCATION Public Right-A-Way
Henderson NV
Subdivision Name: *County:* Clark

2. PLS LOCATION NE ¼ NE ¼ 1 Sec 22 N/S 62 E
PERMIT/WAIVER NO. *Issued by Water Resources* 178-01-599-009 *Current Parcel No.*

Latitude 36*4' 3.16" N UTM E ☐ NAD 27
Longitude 115* 59' 48.26" W UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☒ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☒ Other Direct Push

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	-5
Sandy Silt			-5	15

DOWNWATERS
RECEIVED
APR 18 2015

Date started: 6-Mar , 20 15
Date completed: 6-Mar , 20 15

7. WATER QUALITIES
Static water level: NA Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 0 Feet Depth Cased: 15 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
2	Inches	0	Feet	15	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1/4		Poly Tubbing	+2	14.75

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	0	to	14	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	14	to	15	☐ Pumped	☒ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.01

From	Feet	To	Feet
14.75	Feet	15	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 5241 Schirlls St. Las Vegas, NV 89118 (Contractor)

Nevada contractor's license number as issued by the *State Contractor's Board:* 0075355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2512-LTD

Signed: Bob M
By driller performing actual drilling on site or contractor
Date: 4/15/2015

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.

36.06754
-115.996738