STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122289
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72466

1. OWNER U TURN FOR CHRIST
MAILING ADDRESS 20170 PATTERSON AVE
PARRIS CA 92570

ADDRESS AT WELL LOCATION 3590 W MARS ST
PAHRUMP
Subdivision Name: County: NYE

2. LOCATION NE ¼ NW ¼ Sec 25 T 20S N/S R 52 E
PERMIT/WAIVER No. 27-581-37
Issued by Water Resources Parcel No.

Latitude N36°11"12.8"
Longitude W116°04'10.7"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	110	-110
CALICHIE	WB	110	120	-10
CLAY & GRAVEL		120	140	-20
CALICHIE	WB	140	170	-30
CLAY & GRAVEL		170	180	-10
CALICHIE	WB	180	200	-20

DCNR/DWR/SNR
RECEIVED
APR 08 2015

Date started: 1-Apr , 20 15
Date completed: 3-Apr , 20 15

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (8" SIZE)

		From		To	
9-7/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.37	.248	0	200

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 52 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 52 to 200 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 66 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2513
Signed
By driller performing actual drilling on site or contractor
Date 4/3/2015

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

36.1369282
-116.0771109
NAD 27