STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 12359
Permit No.
Basin No. 141

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73469
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Edwin Dennis Motis
MAILING ADDRESS P.O. Box 705, Tonopah, NV 89049

DETAILED ADDRESS AT WELL LOCATION Block 3 lot 1-4 SE 1/2 Block 3 lot 1-4 NW 1/2
Subdivision Name: Belmont townsite County: NYE

2. PLS LOCATION SE ¼ NW ¼ 26 Sec 9 T 6 S R 45 E
PERMIT/WAIVER NO. 04-533-01
Issued by Water Resources 04-533-01 No.

Latitude 38° 35.709 UTM E ☐ NAD 27
Longitude 116° 52.515 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Alovial			0	10	10
Black shell		108	10	131	121
		115			
Madry 38.595150N 116.525250W					

Date started: 5-6, 20 15
Date completed: 5-7, 20 15

7. WATER QUALITIES
Static water level: 38 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 52 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
55		6

9. WELL CONSTRUCTION
Depth Drilled: Feet Depth Cased: Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11 3/4	Inches	0	Feet	131	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.3	SDR 17	15	131
6 5/8	8	.188	+18	15

PERFORATIONS:
Type of perforation: Mill slot
Size of perforation: .09
From 115 Feet To 130 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0 to 100			
☒ Neat Cement	0 to 20		☐ Pumped	☒ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☒ Bentonite Chips	20 to 100		☐ Pumped	☒ Poured
☐ Bentonite Grout	to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	100 to 131		☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Rosenlund Drilling L.L.C (Contractor)
Address Hc 60 Box 890 Ruby Valley NV 89833 (Contractor)

Nevada contractor's license number as issued by the State Contractor's Board: 0079932
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2465

Signed: Logan Rosenlund (By driller performing actual drilling on site or contractor)
Date: 5-16-15

(Rev. 08-12)
(NSPO Rev 11-12)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627