

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 122356  
Permit No. \_\_\_\_\_  
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70268  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Amelgastom, Rick  
MAILING ADDRESS PO 5181 Inclusive Village SW 89450

DETAILED ADDRESS AT WELL LOCATION 778 Bg Valley Rd

2. PLS LOCATION N 1/4 NW 1/4 26 Sec 11 N/S 21 E  
PERMIT/WAIVER NO. 121-76000005  
Issued by Water Resources Current Parcel No.

Subdivision Name: \_\_\_\_\_ County: Douglas  
Latitude 39.78059 UTM E  NAD 27  
Longitude 119.60364 UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Dirt			0	4	4
Cobbles & Sand			4	89	85
Brown Clay			89	106	17
Granite Boulder			106	115	9
OG			115	202	87
Brown Red Clay			202	213	11
Black Fractured Rock			213	261	48
Red & Grey Clay			261	274	13
Black Fractures			274	326	52
Black, Red Fractured Rock & Clay			326	396	70

9. WELL CONSTRUCTION  
Depth Drilled: 396 Feet  
Depth Cased: 396 Feet

HOLE DIAMETER (BIT SIZE)

From	To	From	To
11	0	70	Feet
			Feet
9 7/8	70	396	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	55	.188	72	396

PERFORATIONS:  
Type of perforation: Factor  
Size of perforation: 1 1/2 x 3  
From 176 / 256 Feet To 196 / 276 Feet  
From 296 / 336 Feet To 316 / 356 Feet  
From 376 Feet To 396 Feet

ANNULAR MATERIALS

Sanitary Seal 0 to 55  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  
 Cement Grout 0 to 55  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  
 Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  
 15 %  20 %  Other, explain: \_\_\_\_\_  
 Gravel Pack [ > 0.2 in. ] 55 to 396  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  
 Other, explain: \_\_\_\_\_

Date started: 4-15-15, 20  
Date completed: 4-17-15, 20

7. WATER QUALITIES  
Static water level: 108 Feet below land surface  
Artesian Flow: 4.9 G.P.M. 45 P.S.I.  
Water Temperature: 63 ° Fahrenheit  
Water Quality: Clear

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name: Blain Drilling Contractor  
Address: PO 1255 Reno NV 89502 Contractor

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>45</u>	<u>4</u>	<u>4</u>

Nevada contractor's license number as issued by the State Contractor's Board: 46908A  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 9391  
Signed: C. Robinson  
By driller performing actual drilling on site or contractor  
Date: 5-8-15