STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

**OFFICE USE ONLY**
Log No. 122359
Permit No.
Basin No. 105

**PRINT OR TYPE IN BLACK INK ONLY**
**DO NOT WRITE ON BACK**

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 20818
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME David Gribaski
MAILING ADDRESS 1422 Sally Lane Gardnerville
DETAILED ADDRESS AT WELL LOCATION 198 Jennie Lane
Subdivision Name: County: Douglas

2. PLS LOCATION NE¼ NE ¼ 09 Sec 12 N/S 19 E
PERMIT/WAIVER NO. 12409.001011
Issued by Water Resources Current Parcel No.
Latitude 38°92384 UTM E ☐ NAD 27
Longitude 119°84481 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

| Material Encountered | Lost Circ. | Water Strata | From | To | Thickness |
|---|---|---|---|---|---|
| over burden | | | 0 | 5 | |
| DG | | | 5 | 38 | |
| clay | | | 38 | 51 | |
| DG | | | 51 | 142 | |
| fractured DG | | X | 142 | 300 | |
| Nad 27 | | | | | |
| 38.923935 N | | | | | |
| 119.843798 W | | | | | |

Date started: 1-29-, 20 15
Date completed: 2-1, 20 15

7. WATER QUALITIES
Static water level: 104 Feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: Cold °Fahrenheit
Water Quality: clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Recorded Time (Hours) |
|---|---|---|
| 25+ | – | 3 |

9. WELL CONSTRUCTION
Depth Drilled: 300 Feet Depth Cased: 300 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 6 7/8 | Inches | 0 Feet | 140 Feet |
| | Inches | 140 Feet | 300 Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | .13 | .188 | +2 | 20 |
| 6" | 4 | SDR21 | 20 | 300 |

PERFORATIONS:
Type of perforation: Factory Screen
Size of perforation: .040
From 240 Feet To 300 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

| | | | | |
|---|---|---|---|---|
| ☒ Sanitary Seal | | to | | |
| ☐ Neat Cement | | to | ☐ Pumped | ☐ Poured |
| ☒ Cement Grout | 0 | to 100 | ☐ Pumped | ☒ Poured |
| ☒ Concrete Grout | | to | ☐ Pumped | ☐ Poured |
| ☐ Bentonite Chips | | to | ☐ Pumped | ☐ Poured |
| ☐ Bentonite Grout | | to | ☐ Pumped | ☐ Poured |
| ☐ 15 % ☐ 20 % ☐ Other, explain: | | | | |
| ☐ Gravel Pack [ > 0.2 in. ] | 100 | to 300 | ☐ Pumped | ☒ Poured |
| ☐ Sand Pack [ < 0.2 in. ] | | to | ☐ Pumped | ☐ Poured |
| ☐ Other, explain: | | to | ☐ Pumped | ☐ Poured |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Blain Drilling (Contractor)
Address PO 1255 CC NV 89702 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 46498A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2134
Signed: (By driller performing actual drilling on site or contractor)
Date: 2/12/15

RECEIVED 2015 MAR 4 PM 1:45 STATE ENGINEER'S OFFICE

(Rev. 08-12)
**USE ADDITIONAL SHEETS IF NECESSARY**
(NSPO Rev 11-12) (O) 627