

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 172361
Permit No. _____
Basin No. 108

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68360
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Jim Chieff
MAILING ADDRESS 26 Fangel Park
NW Virginia, NV 89447

DETAILED ADDRESS AT WELL LOCATION 28 Fangel Park
Subdivision Name: _____ County: MDW

2. PLS LOCATION S 1/4 S 0 3 1/4 13 Sec 26 N/S E
PERMIT/WAIVER NO. 50 012.161.08
Issued by Water Resources Current Parcel No.

Latitude 38 04 39.6 UTM E NAD 27
Longitude 119 11 50.1 UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
<u>100 Soil</u>			<u>0</u>	<u>3</u>	
<u>SAND - Gravel</u>			<u>3</u>	<u>25</u>	
<u>Small Gravel</u>			<u>25</u>	<u>110</u>	
<u>Rock - Black</u>		<u>X</u>	<u>110</u>	<u>139</u>	
<u>fractured Rock</u>			<u>139</u>	<u>200</u>	
<u>Nad 27</u> <u>38.944012 N</u> <u>119.114024 W</u>					

9. WELL CONSTRUCTION

Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>11</u>	<u>0</u>	<u>200</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>20</u>
<u>6</u>	<u>4</u>	<u>SDR21</u>	<u>20</u>	<u>200</u>

PERFORATIONS:

Type of perforation: factory screen
Size of perforation: 1040
From 160 Feet To 200 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

ANNULAR MATERIALS

Sanitary Seal _____ to _____
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout 0 to 50 Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Bentonite Grout _____ to _____ Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] 50 to 200 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 8-17 , 20 12
Date completed: 9-2 , 20 12

7. WATER QUALITIES
Static water level: 55 Feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: 60.0 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA

Test Method:	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<u>18</u>	<u>-</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Blain Drilling
Address: PO Box 12555 Carson City NV 89402

Nevada contractor's license number as issued by the State Contractor's Board: 468907A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): _____
Signed: [Signature]
Date: Sept 18 2012