STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122 365
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69635
WELL NAME (If applicable): 70865

1. OWNER/CLIENT NAME: David Roe
MAILING ADDRESS: 1011 Roop St CCW 89701

DETAILED ADDRESS AT WELL LOCATION: Grand View
1801 Grand ridge
Subdivision Name: County: Douglas

2. PLS LOCATION: SW ¼ SW ¼ 27 Sec 13 N/S 20 E
PERMIT/WAIVER NO. 1320.24.002.009
Issued by Water Resources — Current Parcel No.

Latitude 38° 58.298 UTM E ☐ NAD 27
Longitude 119 41.706 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Dirt			0	15	15
Clay			15	18	3
Gravel			18	55	37
Clay with Sand			55	83	28
Gravel			83	145	62
Sand			145	183	38
Gritty Clay			183	195	12
Sand & Gravel			195	202	7
Small Gravel			202	/	
to Large			/	/	
Gravel			/	280	78
Nad 27					
38.971725 °N					
119.694092 °W					

Date started: 4-30-15, 20
Date completed: 5-2-15, 20

9. WELL CONSTRUCTION
Depth Drilled: 280 Feet Depth Cased: 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	55	Feet
	Inches		Feet		Feet
9 7/8	Inches	55	Feet	280	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	20
6 5/8	4	SDR 21	20	280

PERFORATIONS:
Type of perforation: Factory Cut
Size of perforation: 3/32
From 240 Feet To 280 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☒ Sanitary Seal 0 to 58
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 58 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☒ Gravel Pack [> 0.2 in.] 58 to 280 ☐ Pumped ☒ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 113 Feet below land surface
Artesian Flow: No G.P.M. 40+ P.S.I.
Water Temperature: 59 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
200 Ft	40+		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Blain Well Drilling (Contractor)
Address: PO 1255 CC 89701 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 46498A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2321
Signed: C. Robinson (By driller performing actual drilling on site or contractor)
Date: 5-8-15

RECEIVED 2015 MAY 11 PM 3:
STATE ENGINEER OFFICE

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY
(NSPO Rev 11-12)
(O) 627