STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122373
Permit No.
Basin No. 089

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71611
WELL NAME

1. OWNER CLIENT NAME: Pamela Wilcox
MAILING ADDRESS: 2955 Falcon Street
Washoe Valley, NV 89704
NW

DETAILED ADDRESS AT WELL LOCATION: 2955 Falcon Street
Washoe Valley, NV 89704
Subdivision Name: County: Washoe

2. PLS LOCATION: ~~SE~~ ¼ ~~NW~~ ¼ 31 17N 20
PERMIT WAIVER NO. 50 | 050-407-13
Lat. 39.29208 UTM ☐ NAD 27
Long. -119.77595 UTM ■ NAD 83 WGS 84

3. WORKED PERFORMED
☐ New Well ■ Deepen Orig WL#
☐ Replacement Original well log #
☐ Recondition Original well log #

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ■ Rotary ☐ RVC
■ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered			From	To
Green and black d g			97	203
T.D. = 203				
Nad 27				
39.292130°N				
119.774932°W				
deepens unknown log				

Date Started: 29-Apr 20 15
Date Completed: 1-May 20 15

7. WATER QUALITY
Static water level: 80 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 ° Fahrenheit
Water Quality: Clean

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20+		1 hr

9. INSTRUCTION
Depth Drilled: 203 Feet Depth Cased: 203 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/4	Inches	97	Feet	203	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.25	.188	70	203

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain to ☐ Pumped ☐ Poured

PERFORATIONS
Type of perforation: Factory
Size of perforation: 3/32 x 3
From 183 Feet To 203 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: A.S.A.P.Pump & Well Service,LLC. (Contractor)
Address: P.O. Box 60130 Reno, Nevada 89506 (Contractor)
Nevada contractor's license number as issued by the Contractor's Board: 35307C
Nevada well driller's license number as issued by the Nevada Division of Water Resources of Nevada: 2362
Larry Welch
5-6-15

RECEIVED
2015 MAY 14 AM 11:28
STATE ENGINEERS OFFICE

(Rev. 12-13)
USE ADDITIONAL SHEETS IF NECESSARY
pg. 1 of pg. 1