STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 172417
Permit No.
Basin No. 070

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72644
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Gerald Stanton
MAILING ADDRESS 3360 Silver Sage Ave
Fallon NV

DETAILED ADDRESS AT WELL LOCATION Off of Elk Lane
Winnemucca NV
Subdivision Name: Grass Valley Ranchos *County:* Humboldt

2. PLS LOCATION SW ¼ NE ¼ 25 Sec 35 N/S 36 E
PERMIT/WAIVER NO. *Issued by Water Resources* 353625200014 *Current Parcel No.*

Latitude N40°52'56.353" UTM E ☐ NAD 27
Longitude W117°52'46.260" UTM N ☒ NAD 83/WGS 84

3. **WORKED PERFORMED**
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. **WELL TYPE**
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. **LITHOLOGIC LOG**

Material Encountered	Lost Circ.	Water Strata	From	To
Sand		No	0	5
Caliche		No	5	10
Cemented gravel cobbles clay		No	10	115
Cemented gravel cobbles clay		Yes	115	200

NAD27
40.882416°N
117.878416°W

Date started: 10-Apr , 20 15
Date completed: 04/14/15 , 20 15

7. *WATER QUALITIES*
Static water level: 112 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 °Fahrenheit
Water Quality: Clear

8. **WELL TEST DATA**
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25	N/A	6

9. *CONSTRUCTION*
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8"	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	steel	.188	0	20
6 5/8"	pvc	Sched 40	20	200

ANNULAR MATERIALS
Sanitary Seal X ☒ Yes ☐ No X

☒ Neat Cement	0	to 20	☐ Pumped	☒ X Poured	
☐ Cement Grout		to	☐ Pumped	☐ Poured	
☐ Concrete Grout		to	☐ Pumped	☐ Poured	
☒ Bentonite Chips	20	to 50	☐ Pumped	☒ Poured	
☐ Gravel Pack [> 0.2 in.]	50	to 200	☐ Pumped	☒ Poured	
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured	
☐ Other, explain:		to	☐ Pumped	☐ Poured	

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.2

From	Feet	To	Feet
160	Feet	200	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Allied Drilling Inc. *Contractor*
Address 5140 Jungo Rd Winnemucca NV *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 26778
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 730

Signed: *By driller performing actual drilling on site or contractor*
Date: 4-20-15

RECEIVED 2015 MAY 11 PM 1:15 STATE ENGINEER'S OFFICE

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.