ORIGINAL

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122421
Permit No. 28803
Basin No. 033A

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72057
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Gary VanVliet
MAILING ADDRESS 26257 Matthews Road
Parma, ID 83660

DETAILED ADDRESS AT WELL LOCATION
Corner of US95N and Codr Road Orvada, NV .14 miles West on Codr Rd
Subdivision Name: County: Humboldt

2. PLS LOCATION NE ¼ NE ¼ 2 Sec 44 N/S 37 E
PERMIT/WAIVER NO. 28803 (Issued by Water Resources) Current Parcel No.

Latitude 41° 43.729'N UTM E ☐ NAD 27
Longitude 117° 46.142'W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☒ Recondition: Original well log # 5107

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / GM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Existing casing 16" x 0.187"			0	262
Open hole			262	410
Notes:				
Installed liner				
NAD27				
41.728923°N				
117.768059°W				

Date started: 20-Apr , 20 15
Date completed: 20-Apr , 20 15

7. WATER QUALITIES
Static water level: 175 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: Feet Depth Cased: Feet

HOLE DIAMETER (BIT SIZE)
SEE LOG # 5107 From To
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		0.250"	0	260

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

PERFORATIONS:
Type of perforation: 14" Mill slot double row 0.80 slot
Size of perforation: 12 3/4" Mill slot triple row 0.80 slot
From 14": 260 Feet To 300 Feet
From 12x14 reducer Feet To Feet
From 12.75" OD: 301 Feet To 401 Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Hydro Resources West, Inc. Contractor
Address 4975 West Winnemucca Blvd. Winnemucca, NV 89445 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 56797
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 01345
Signed: [signature] (If driller performing actual drilling on site or contractor)
Date: 4-20-15

RECEIVED
2015 MAY -7 AM 11:05
STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Reconditions Well log 5107