ORIGINAL

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122422
Permit No. 20282
Basin No. 070

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72056
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Jim Thompson
MAILING ADDRESS 5750 E 2nd Street
Winnemucca, NV 89445

DETAILED ADDRESS AT WELL LOCATION 1.12 miles NE of Rhinehart Ln on East 2nd Street. Left (North) on road onto property .19 miles
Subdivision Name:
County: Humbolt

2. PLS LOCATION sw ¼ se ¼ 9 Sec 36 N/S 38 E
PERMIT/WAIVER NO. 20282 (Issued by Water Resources) (Current Parcel No.)

Latitude 41° 0.372'N UTM E ☐ NAD 27
Longitude 117° 42.298'W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☒ Recondition: Original well log # 7900

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Existing casing 16" x .250"			0	236
Open hole			236	252
NOTES:				
Installed liner				
NAD27				
41.006298°N				
117.704005°W				

Date started: 21-Apr, 20 15
Date completed: 4/21/15, 20 15

7. WATER QUALITIES
Static water level: 23' Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 252 Feet Depth Cased: 236 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
SEE LOG # 7900 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		1/4" wall	0	26

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

PERFORATIONS:
Type of perforation: Mill slot triple row
Size of perforation: 0.08

From	Feet	To	Feet
14" OD -26'		166'	
12x14 reducer			
12.75" OD 166'		246'	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Hydro Resources West, Inc. (Contractor)
Address 4975 West Winnemucca Blvd. Winnemucca, NV 89445 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 58797
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on site driller): 07375
Signed: (by driller performing actual drilling on site or contractor)
Date: April 21 2015

RECEIVED 2015 MAY 17 AM 10:04 STATE ENGINEERS OFFICE

(Rev. 12-13)
USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Reconditioned Well log 7900