STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122437
Permit No.
Basin No. 107

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72928
WELL NAME *(If applicable)*: MW-2

1. OWNER/CLIENT NAME: Dirk Vlot
MAILING ADDRESS: PO Box 497 Wellington, NV 89444

DETAILED ADDRESS AT WELL LOCATION: 40 Hunewill Lane
Wellington NV
Subdivision Name: *County:* Lyon

2. PLS LOCATION: SE ¼ SW ¼ 23 Sec 12 N/S 23 E
PERMIT/WAIVER NO. 1983 *Issued by Water Resources* 010-111-02 *Current Parcel No.*

Latitude 38* 53' 07.37" N UTM E ☒ NAD 27
Longitude 115* 22' 41.15" W UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sandy Silt			0	10
Silty Sand			10	15
Silt			15	17
Sand			17	27
Sandy Clay			27	37

DCNR/DWR/SNRO
RECEIVED
MAY 06 2015
NAD 27
38.885468°N
119.377103°W

Date started: 25-Mar , 20 15
Date completed: 25-Mar , 20 15

9. INSTRUCTION
Depth Drilled: 37 Feet Depth Cased: 37 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.25	Inches	0	Feet	37	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	37

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0.5	to 8	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	8	to 10	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	10	to 37	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

From	Feet	To	Feet
12		37	

7. WATER QUALITIES
Static water level: 11.8 Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP *Contractor*
Address: 5241 Schirlls St. Las Vegas, NV 89118 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board*: 0075355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2512-LTD
Signed: Bob Ho *By driller performing actual drilling on site or contractor*
Date: 4/15/2015

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.