STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122448
Permit No.
Basin No. 049

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72927
WELL NAME *(If applicable)*: MW-5

1. OWNER/CLIENT NAME: Hardy Enterprise Inc.
MAILING ADDRESS: 598 W. 2600 South, Bountiful, UT 84010

DETAILED ADDRESS AT WELL LOCATION: 1790 Idaho St, Elko, NV
Subdivision Name: *County:* Elko

2. PLS LOCATION: SE ¼ SW ¼ 11 Sec 34 (N) 55 E
PERMIT/WAIVER NO. 1984 *Issued by Water Resources* 001-590-004 *Current Parcel No.*

Latitude 40.842328 UTM E ☒ NAD 27
Longitude 115.751182 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	-5
TYPE II Base			-5	2
Silt			2	15
Gravel fine med round			15	17
Silty Sand			17	22
Clay			22	27
Damp Stiff Silt w/ some sand			27	35
Moist dense sand,silty, sand			35	40
Stifff silt w/some clay			40	75

DCNR/DWR/SNBC
RECEIVED
MAY 06 2015

Date started: 7-Apr, 20 15
Date completed: 7-Apr, 20 15

9. CONSTRUCTION
Depth Drilled: 75 Feet Depth Cased: 75 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	75	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.500	2.01	0.237	0	75

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	1.5	to 31	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☒ Concrete Grout	0	to 1.5	☐ Pumped	☒ Poured
☒ Bentonite Chips	31	to 33	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	33	to 75	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

From	To
35 Feet	75 Feet
Feet	Feet
Feet	Feet
Feet	Feet
Feet	Feet

7. WATER QUALITIES
Static water level: 47' Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP *Contractor*
Address: 5241 Schirlls St. Las Vegas, NV 89118 *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board*: 0075355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2512-LTD

Signed: Bob [illegible] *By driller performing actual drilling on site or contractor*
Date: 4/29/2015

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.