STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122450
Permit No.
Basin No. 049

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72927
WELL NAME (If applicable): MW-6

1. OWNER/CLIENT NAME: Hardy Enterprise Inc.
MAILING ADDRESS: 598 W. 2600 South, Bountiful, UT 84010

DETAILED ADDRESS AT WELL LOCATION: 1790 Idaho St, Elko, NV
Subdivision Name:
County: Elko

2. PLS LOCATION: SE ¼ SW ¼ 11 Sec 34 N 55 E
PERMIT/WAIVER NO. 1984 (Issued by Water Resources) 001-590-004 (Current Parcel No.)

Latitude 40.842553 UTM E ☒ NAD 27
Longitude 115.751733 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	-5
TYPE II Base			-5	2
Silt			2	15
Gravel fine med round			15	17
Silty Sand			17	22
Clay			22	25
Damp Stiff Silt w/ some sand			25	29
Moist dense sand,silty, sand			29	42
Stifff silt w/some clay/sand			42	75

DCNR/DWR/SNBC
RECEIVED
MAY 06 2015

Date started: 8-Apr, 20 15
Date completed: 8-Apr, 20 15

9. INSTRUCTION
Depth Drilled: 75 Feet Depth Cased: 75 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10.25 Inches		0 Feet	75 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.500	2.01	0.237	0	75

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☒ Neat Cement	1.5	to 31	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☒ Concrete Grout	0	to 1.5	☐ Pumped	☒ Poured
☒ Bentonite Chips	31	to 33	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	33	to 75	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

From 35 Feet	To 75 Feet		
From Feet	To Feet		
From Feet	To Feet		
From Feet	To Feet		
From Feet	To Feet		

7. WATER QUALITIES
Static water level: 48 Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP (Contractor)
Address: 5241 Schirlls St. Las Vegas, NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD
Signed: Bob H (By driller performing actual drilling on site or contractor)
Date: 4/29/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.