

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT**

OFFICE USE ONLY
Log No. 122581
Permit No. _____
Basin No. 090

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71436
WELL NAME (if applicable): well#1

1. OWNER/CLIENT NAME Kingsbury General Improvement Dist.
MAILING ADDRESS 255 Kingsbury Grade, Suite A
Stateline NV 89449

DETAILED ADDRESS AT WELL LOCATION 399 Eugene Dr. Stateline NV
89449

2. PLS LOCATION NW ¼ SW ¼ 22 Sec 13 N N/S 18 E
PERMIT/WAIVER NO. DW-113 R-856 1318-22-002-001
Issued by Water Resources Current Parcel No.

Subdivision Name _____ County: Douglas
Latitude 38.97518 N UTM E NAD 27
Longitude 119.951049 W UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic
 Mining / Dewater
 Test / Other
 Irrigation Monitor
 Com / Ind Stock
 Mun / CM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
Other _____

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Tan silty sand			0	6
Tan silty sand-gray silty sand			6	22
Gray silty sand			22	40
Annular Materials				
0-10' - Steel Spacer				
10'-12' - Bentonite Seal				

9. INSTRUCTION

Depth Drilled: 40 Feet Depth Cased: 40 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>24</u> Inches	<u>0</u> Feet <u>40</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>6</u>	<u>3/8</u>	<u>0</u>	<u>40</u>

ANNULAR MATERIALS

Sanitary Seal Yes No

Neat Cement _____ to _____ Pumped Poured

Cement Grout _____ to _____ Pumped Poured

Concrete Grout _____ to _____ Pumped Poured

Bentonite Chips _____ to _____ Pumped Poured

Gravel Pack [> 0.2 in.] 12 to 40 Pumped Poured

Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured

Other, explain: _____ to _____ Pumped Poured

3/8 pea gravel

Date started: 20-May, 20 15
Date completed: 21-May, 20 15

PERFORATIONS:

Type of perforation: machine slot
Size of perforation: 0.032

From 20 Feet To 40 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

7. WATER QUALITIES

Static water level: 8ft Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ ° Fahrenheit
Water Quality: _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Viking Drillers, Inc Contractor
Address 5950 Granite Lake Drive, Granite Bay, CA 95746 Contractor

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

Nevada contractor's license number as issued by the State Contractor's Board: 0034660
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2381

Signed: [Signature]
By driller performing actual drilling on site or contractor's

Date: 6/3/2015

RECEIVED
25 JUN - 8 14 19
STATE ENGINEERS OFFICE