STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122586
Permit No.
Basin No. 090

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71436
WELL NAME (If applicable): well#6

1. OWNER/CLIENT NAME: Kingsburry General Improvement Dist.
MAILING ADDRESS: 255 Kingsburry Grade, Suite A
Stateline NV 89449

DETAILED ADDRESS AT WELL LOCATION: 399 Eugene Dr. Stateline NV 89449
Subdivision Name: County:

2. PLS LOCATION: NW ¼ SW ¼ 22 Sec 13 N N/S 18 E
PERMIT/WAIVER NO.: DW-113 R-856 (Issued by Water Resources) 1318-22-002-001 (Current Parcel No.)

Latitude: 38.975092 N
Longitude: 119.951053 W
UTM E:
UTM N:
☐ NAD 27
x NAD 83/WGS 84

3. WORKED PERFORMED
x New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
x Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
x Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Tan silty sand			0	4
Tan silty sand - silty sand touch			4	20
of clay				
Annular Materials				
0-10' - Steel Spacer				
10'-12' - Bentonite Seal				
NAD 27				
38.975184°N				
119.950039°W				
Plugged by well				
log 124499				

Date started: 20-May, 20 15
Date completed: 21-May, 20 15

7. WATER QUALITIES
Static water level: 8ft Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 20 Feet Depth Cased: 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
30	Inches	0 Feet	20 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	3/8	0	20

ANNULAR MATERIALS
Sanitary Seal Yes ☐ No

☐ Neat Cement	to	☐ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
Bentonite Chips	to	☐ Pumped	Poured
x Gravel Pack [> 0.2 in.] 12	to 20	☐ Pumped	x Poured
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured
☐ Other, explain: 3/8 pea gravel	to	☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: machine slot
Size of perforation: 0.032

From	To
0 Feet	20 Feet
Feet	Feet
Feet	Feet
Feet	Feet
Feet	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Viking Drillers, Inc (Contractor)
Address: 5950 Granite Lake Drive, Granite Bay, CA 95746 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0034680
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2381
Signed: (By driller performing actual drilling on site or contractor)
Date: 6/3/2015

RECEIVED 2015 JUN -8 PM 1:49 STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.