STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122596
Permit No.
Basin No. 072

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72255
WELL NAME (if applicable): MW-19

1. OWNER/CLIENT NAME Travel Centers of America
MAILING ADDRESS 24601 Center Ridge Rd Ste 200 West Lake Ohio 44145

DETAILED ADDRESS AT WELL LOCATION Travel Center of America 6000 Frontage Rd Mill City NV
Subdivision Name: County: Pershing

2. PLS LOCATION NW ¼ NW ¼ 33 Sec 33 N S 35 E
PERMIT/WAIVER NO. MW 1995 (Issued by Water Resources) 008-130-01 (Current Parcel No.)

Latitude N 40° 41.622' UTM E ☐ NAD 27
Longitude W 118° 03.401' UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

MW-19 Material Encountered	Lost Circ.	Water Strata	From	To
Silt Sand Gravel			0	35
Sand Silt Gravel		Yes	35	70
NAD27				
40.693783°N				
118.056717°W				

Date started: 5/13, 20 15
Date completed: 5/13, 20 15

7. WATER QUALITIES
Static water level: 60 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 85 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 70 Feet Depth Cased: 70 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	70	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Schedule 40	0	70

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to 33	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	33	to 53	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	53	to 70	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory Slot
Size of perforation: 0.010
From 55 Feet To 70 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc (Contractor)
Address P.O. Box 940 Meridian Id 83680 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0038018
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2412 RTD
Signed: [signature] By driller performing actual drilling on site or contractor
Date: 6/4/15

RECEIVED 2015 JUN -8 PM 4:48 STATE ENGINEERS OFFICE

(Rev 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.