STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122612
Permit No.
Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71285

1. OWNER David & Pat Canter
MAILING ADDRESS 4840 Piper Drive

ADDRESS AT WELL LOCATION 4840 Piper Drive
Winnemucca, NV 89445
Subdivision Name: Airport Estates *County:* Humboldt

2. LOCATION SW¼NW¼ Sec23T35N/ R37E
PERMIT/WAIVER NO. N/A (*Issued by Water Resources*) 3537-23-100-024 (Parcel. No.)

Latitude 40.53'42.84" UTM E ☐ NAD 27
Longitude 117.47'28.86 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		100	105	5
Clay		105	125	20
Sand/Gravel	X	125	170	45
Clay		170	172	2
Gravel/Sand	X	172	195	23

Nad27
lat 40.59332°N
lon 117.79038°W
deepen unknown log

Date started: April 22, 20 15
Date completed: April 23, 20 15

7. *Water Level*
Static water level: 70 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-20		4

9. *WELL CONSTRUCTION*
Depth Drilled 195 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	100 Feet	195 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8.06	.188	95	195

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32X4
From 155 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 021467
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2083
Signed
By driller performing actual drilling on site or contractor
Date May 13, 2015

RECEIVED 2015 MAY 18 AM 11:45 STATE ENGINEERS OFFICE

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com