STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122635
Permit No.
Basin No. 070

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ~~72654~~ 72654
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Linda Cole
MAILING ADDRESS 8465 S. Stinson
Winnemucca NV. 89445

DETAILED ADDRESS AT WELL LOCATION 8465 S. Stinson
Winnemucca NV.
Subdivision Name: *County:* Humboldt

2. PLS LOCATION SW ¼ NW ¼ 24 Sec 35 N/S 37 E
PERMIT/WAIVER NO. 3537-24-151-004
Issued by Water Resources *Current Parcel No.*

Latitude N40*53'40.862 UTM E ☐ NAD 27
Longitude W117*46'29.53 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# ?
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Existing well 6" casing		No	0	120
gravel sand clay		Yes	120	220

NAD 27
40.894780°N
117.773908°W

Date started: 4-Jun , 20 15
Date completed: 06/08/15 , 20 15

7. WATER QUALITIES
Static water level: 107 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	N/A	4

9. CONSTRUCTION
Depth Drilled: 220 Feet Depth Cased: 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	120	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	pvc	Sced 40	110	220

ANNULAR MATERIALS

Sanitary Seal ☐ Yes ☒ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

PERFORATIONS:

Type of perforation: slot
Size of perforation: 0.02

From 180	Feet	To 220	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd Winnemucca NV
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 76778
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2508

Signed:
By driller performing actual drilling on site or contractor
Date: 6-8-15

2015 JUN 25 PM 12:40
STATE ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Deepens Unknown Well log